

Tampa, FL

City Of Tampa Water Department · Surface water

EPA PWSID: FL6290327

DATA: EPA SDWIS · UCMR5

LAST READING: DEC 2025

WATERHEALTHCHECK.COM



Poor

18 above EWG health guideline
2 above EPA legal limit
50 contaminants monitored

Poor — with 20 concerns

City Of Tampa Water Department has 2 contaminants above EPA legal limits and 18 above EWG health guidelines.

CONTAMINANTS TESTED 50 TOTAL

CONTAMINANT	VS MCL	LEVEL	STATUS
PFOS (perfluorooctane sulfonate) CAS 1763-23-1	<div style="width: 100%;"><div style="width: 100%;"></div></div>	5.4 ppt	• ABOVE EPA LIMIT
PFOA (perfluorooctanoic acid) CAS 335-67-1	<div style="width: 100%;"><div style="width: 100%;"></div></div>	4.5 ppt	• ABOVE EPA LIMIT
Haloacetic acids (HAA5) CAS Various	<div style="width: 100%;"><div style="width: 32.5%;"></div></div>	32.5 ppb	• ABOVE GUIDELINE
Total trihalomethanes (TTHMs) CAS Various	<div style="width: 100%;"><div style="width: 35.3%;"></div></div>	35.3 ppb	• ABOVE GUIDELINE
Bromodichloromethane CAS 75-27-4	<div style="width: 100%;"><div style="width: 13.9%;"></div></div>	13.9 ppb	• ABOVE GUIDELINE
Dichloroacetic acid (DCA) CAS 79-43-6	<div style="width: 100%;"><div style="width: 25.0%;"></div></div>	25.0 ppb	• ABOVE GUIDELINE
Bromate CAS 15541-45-4	<div style="width: 100%;"><div style="width: 8.2%;"></div></div>	8.2 ppb	• ABOVE GUIDELINE
Chloroform (trichloromethane) CAS 67-66-3	<div style="width: 100%;"><div style="width: 16.1%;"></div></div>	16.1 ppb	• ABOVE GUIDELINE
Trichloroacetic acid (TCA) CAS 76-03-9	<div style="width: 100%;"><div style="width: 1.9%;"></div></div>	1.9 ppb	• ABOVE GUIDELINE
Dibromochloromethane CAS 124-48-1	<div style="width: 100%;"><div style="width: 7.1%;"></div></div>	7.1 ppb	• ABOVE GUIDELINE
Dibromoacetic acid (DBAA) CAS 631-64-1	<div style="width: 100%;"><div style="width: 3.6%;"></div></div>	3.6 ppb	• ABOVE GUIDELINE
Monochloroacetic acid (MCAA) CAS 79-11-8	<div style="width: 100%;"><div style="width: 5.1%;"></div></div>	5.1 ppb	• ABOVE GUIDELINE

Monobromoacetic acid (MBAA) <small>CAS 79-08-3</small>		2.5 ppb	• ABOVE GUIDELINE
PFHxS (perfluorohexane sulfonic acid) <small>CAS 355-46-4</small>		3.9 ppt	• ABOVE GUIDELINE
PFHpA (perfluoroheptanoic acid) <small>CAS 375-85-9</small>		3.9 ppt	• ABOVE GUIDELINE
PFBA (perfluorobutanoic acid) <small>CAS 375-22-4</small>		6.1 ppt	• ABOVE GUIDELINE
PFPeA (perfluoropentanoic acid) <small>CAS 2706-90-3</small>		6.5 ppt	• ABOVE GUIDELINE
Nitrate <small>CAS 14797-55-8</small>		0.30 ppm	• ABOVE GUIDELINE
PFHxA (perfluorohexanoic acid) <small>CAS 307-24-4</small>		5.0 ppt	• ABOVE GUIDELINE
Lead <small>CAS 7439-92-1</small>		1.5 ppb	• ABOVE GUIDELINE
PFBS (perfluorobutane sulfonic acid) <small>CAS 375-73-5</small>		4.4 ppt	• WITHIN LIMITS
Bromoform (tribromomethane) <small>CAS 75-25-2</small>		2.9 ppb	• WITHIN LIMITS
Turbidity		0.09 NTU	• WITHIN LIMITS
Fluoride <small>CAS 16984-48-8</small>		0.62 ppm	• WITHIN LIMITS
Barium <small>CAS 7440-39-3</small>		0.01 ppm	• WITHIN LIMITS
Benzene <small>CAS 71-43-2</small>		ND	• NOT DETECTED
Tetrachloroethylene (PCE) <small>CAS 127-18-4</small>		ND	• NOT DETECTED
Nitrite <small>CAS 14797-65-0</small>		ND	• NOT DETECTED
Trichloroethylene (TCE) <small>CAS 79-01-6</small>		ND	• NOT DETECTED
Selenium <small>CAS 7782-49-2</small>		ND	• NOT DETECTED
Arsenic <small>CAS 7440-38-2</small>		ND	• NOT DETECTED
Mercury (inorganic) <small>CAS 7439-97-6</small>		ND	• NOT DETECTED
HFPO-DA / GenX (hexafluoropropylene oxide dimer acid) <small>CAS 13252-13-6</small>		ND	• NOT DETECTED
ADONA (4,8-dioxa-3H-perfluorononanoic acid) <small>CAS 919005-14-4</small>		ND	• NOT DETECTED
PFHpS (perfluoroheptane sulfonic acid) <small>CAS 375-92-8</small>		ND	• NOT DETECTED
11Cl-PF3OUdS (11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid) <small>CAS 763051-92-9</small>		ND	• NOT DETECTED

6:2 FTS (6:2 fluorotelomer sulfonic acid) CAS 27619-97-2		ND	● NOT DETECTED
PFPeS (perfluoropentane sulfonic acid) CAS 2706-91-4		ND	● NOT DETECTED
Lithium CAS 7439-93-2		ND	● NOT DETECTED
PFTA (perfluorotetradecanoic acid) CAS 376-06-7		ND	● NOT DETECTED
8:2 FTS (8:2 fluorotelomer sulfonic acid) CAS 39108-34-4		ND	● NOT DETECTED
PFDA (perfluorodecanoic acid) CAS 335-76-2		ND	● NOT DETECTED
PFNA (perfluorononanoic acid) CAS 375-95-1		ND	● NOT DETECTED
9CI-PF3ONS (9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid) CAS 756426-58-1		ND	● NOT DETECTED
4:2 FTS (4:2 fluorotelomer sulfonic acid) CAS 757124-72-4		ND	● NOT DETECTED
PFTrDA (perfluorotridecanoic acid) CAS 72629-94-8		ND	● NOT DETECTED
PFDoA (perfluorododecanoic acid) CAS 307-55-1		ND	● NOT DETECTED
PFUnA (perfluoroundecanoic acid) CAS 2058-94-8		ND	● NOT DETECTED
NEtFOSAA (N-ethyl perfluorooctane sulfonamido acetic acid) CAS 2991-50-6		ND	● NOT DETECTED
NMeFOSAA (N-methyl perfluorooctane sulfonamido acetic acid) CAS 2355-31-9		ND	● NOT DETECTED

WATER WELLNESS · DRAWN HEALTH

Want to go further than filtration?

Your report shows 20 contaminants above health guidelines. A specialist at Drawn can give you an expert read on your specific profile — what to prioritise, which filters actually address it, and what optimisation looks like for your household.

WHAT A CONSULTATION COVERS

- ✓ Your contaminant profile explained in plain English
- ✓ Filter recommendations matched to what's actually in your water
- ✓ Optimisation options for households ready for that conversation

[Talk to a specialist at Drawn →](#)

20 min · Free · No obligation

DATA SOURCES & METHODOLOGY

WaterHealthCheck is an independent water-health information service. We do not sell water filters. This report is for informational purposes only and does not constitute medical advice.

waterhealthcheck.com · Dec 2025

Contaminant data from EPA Safe Drinking Water Information System (SDWIS), PWSID FL6290327, most recent monitoring period. PFAS data from UCMR5 (Unregulated Contaminant Monitoring Rule 5, 2023–2025). Status flags compare detected levels against EPA Maximum Contaminant Levels (legal limits) and EWG health-based guidelines (peer-reviewed, stricter). Full methodology at waterhealthcheck.com/methodology.

WaterHealthCheck is an independent water-health information service. We do not sell water filters. This report is for informational purposes only and does not constitute medical advice.

waterhealthcheck.com · Dec 2025