

# Cincinnati, OH

Cincinnati Public Water System · Surface water

EPA PWSID: OH3102612

DATA: EPA SDWIS · UCMR5

LAST READING: JUL 2026

WATERHEALTHCHECK.COM



## Fair

2 above EWG health guideline

1 above EPA legal limit
















27 contaminants monitored

## Fair — with 3 concerns

Cincinnati Public Water System has 1 contaminant above EPA legal limits and 2 above EWG health guidelines.

CONTAMINANTS TESTED 27 TOTAL

CONTAMINANT	VS MCL	LEVEL	STATUS
PFOS (perfluorooctane sulfonate) CAS 1763-23-1	<div style="width: 100%;"></div>	5.2 ppt	• ABOVE EPA LIMIT
PFBA (perfluorobutanoic acid) CAS 375-22-4	<div style="width: 100%;"></div>	5.2 ppt	• ABOVE GUIDELINE
Lead CAS 7439-92-1	<div style="width: 10%;"></div>	1.9 ppb	• ABOVE GUIDELINE
PFBS (perfluorobutane sulfonic acid) CAS 375-73-5	<div style="width: 100%;"></div>	3.9 ppt	• WITHIN LIMITS
4:2 FTS (4:2 fluorotelomer sulfonic acid) CAS 757124-72-4	<div style="width: 100%;"></div>	ND	• NOT DETECTED
6:2 FTS (6:2 fluorotelomer sulfonic acid) CAS 27619-97-2	<div style="width: 100%;"></div>	ND	• NOT DETECTED
HFPO-DA / GenX (hexafluoropropylene oxide dimer acid) CAS 13252-13-6	<div style="width: 100%;"></div>	ND	• NOT DETECTED
9CI-PF3ONS (9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid) CAS 756426-58-1	<div style="width: 100%;"></div>	ND	• NOT DETECTED
PFDoA (perfluorododecanoic acid) CAS 307-55-1	<div style="width: 100%;"></div>	ND	• NOT DETECTED
PFHxA (perfluorohexanoic acid) CAS 307-24-4	<div style="width: 100%;"></div>	ND	• NOT DETECTED
PFUnA (perfluoroundecanoic acid) CAS 2058-94-8	<div style="width: 100%;"></div>	ND	• NOT DETECTED
ADONA (4,8-dioxa-3H-perfluorononanoic acid) CAS 919005-14-4	<div style="width: 100%;"></div>	ND	• NOT DETECTED

<b>PFTrDA (perfluorotridecanoic acid)</b> CAS 72629-94-8		ND	● NOT DETECTED
<b>PFPeS (perfluoropentane sulfonic acid)</b> CAS 2706-91-4		ND	● NOT DETECTED
<b>PFHpS (perfluoroheptane sulfonic acid)</b> CAS 375-92-8		ND	● NOT DETECTED
<b>Lithium</b> CAS 7439-93-2		ND	● NOT DETECTED
<b>PFHpA (perfluoroheptanoic acid)</b> CAS 375-85-9		ND	● NOT DETECTED
<b>PFTA (perfluorotetradecanoic acid)</b> CAS 376-06-7		ND	● NOT DETECTED
<b>PFOA (perfluorooctanoic acid)</b> CAS 335-67-1		ND	● NOT DETECTED
<b>NEtFOSAA (N-ethyl perfluorooctane sulfonamido acetic acid)</b> CAS 2991-50-6		ND	● NOT DETECTED
<b>PFPeA (perfluoropentanoic acid)</b> CAS 2706-90-3		ND	● NOT DETECTED
<b>PFHxS (perfluorohexane sulfonic acid)</b> CAS 355-46-4		ND	● NOT DETECTED
<b>PFNA (perfluorononanoic acid)</b> CAS 375-95-1		ND	● NOT DETECTED
<b>11Cl-PF3OUdS (11-chloroeicosafuoro-3-oxaundecane-1-sulfonic acid)</b> CAS 763051-92-9		ND	● NOT DETECTED
<b>8:2 FTS (8:2 fluorotelomer sulfonic acid)</b> CAS 39108-34-4		ND	● NOT DETECTED
<b>NMeFOSAA (N-methyl perfluorooctane sulfonamido acetic acid)</b> CAS 2355-31-9		ND	● NOT DETECTED
<b>PFDA (perfluorodecanoic acid)</b> CAS 335-76-2		ND	● NOT DETECTED

## Want to go further than filtration?

Your report shows 3 contaminants above health guidelines. A specialist at Drawn can give you an expert read on your specific profile — what to prioritise, which filters actually address it, and what optimisation looks like for your household.

### WHAT A CONSULTATION COVERS

- ✓ Your contaminant profile explained in plain English
- ✓ Filter recommendations matched to what's actually in your water
- ✓ Optimisation options for households ready for that conversation

[Talk to a specialist at Drawn →](#)

20 min · Free · No obligation

### DATA SOURCES & METHODOLOGY

Contaminant data from EPA Safe Drinking Water Information System (SDWIS), PWSID OH3102612, most recent monitoring period. PFAS data from UCMR5 (Unregulated Contaminant Monitoring Rule 5, 2023–2025). Status flags compare detected levels against EPA Maximum Contaminant Levels (legal limits) and EWG health-based guidelines (peer-reviewed, stricter). Full methodology at [waterhealthcheck.com/methodology](https://waterhealthcheck.com/methodology).

WaterHealthCheck is an independent water-health information service. We do not sell water filters. This report is for informational purposes only and does not constitute medical advice.

[waterhealthcheck.com](https://waterhealthcheck.com) · Jul 2026