

Fort Worth, TX

Fort Worth Water Department · Surface water · Trinity River watershed — Eagle Mountain Lake and Lake Bridgeport (Upper Trinity, operated by Tarrant Regional Water District), plus Richland-Chambers Reservoir and Cedar Creek Reservoir (supplied by Tarrant Regional Water District from East Texas). Treated at the Rolling Hills Water Treatment Plant. Free chlorine disinfection. Fluoridated at 0.7 ppm.

EPA PWSID: TX2200012

DATA: EPA SDWIS · UCMR5

LAST READING: JUL 2026

WATERHEALTHCHECK.COM



Poor

- 7 above EWG health guideline
- 3 above EPA legal limit
- 32 contaminants monitored

Poor — with 10 concerns

Fort Worth Water Department has 3 contaminants above EPA legal limits and 7 above EWG health guidelines. Lead levels within limits at treatment plant

● LEAD LEVELS WITHIN LIMITS AT TREATMENT PLANT

CONTAMINANT	VS MCL	LEVEL	STATUS
PFOS (perfluorooctane sulfonate) CAS 1763-23-1		5.7 ppt	● ABOVE EPA LIMIT
PFOA (perfluorooctanoic acid) CAS 335-67-1		5.7 ppt	● ABOVE EPA LIMIT
PFHxS (perfluorohexane sulfonic acid) CAS 355-46-4		14.9 ppt	● ABOVE EPA LIMIT
Haloacetic acids (HAA5) CAS Various		34.6 ppb	● ABOVE GUIDELINE
Total trihalomethanes (TTHMs) CAS Various		51.3 ppb	● ABOVE GUIDELINE
PFBA (perfluorobutanoic acid) CAS 375-22-4		7.6 ppt	● ABOVE GUIDELINE
PFPeA (perfluoropentanoic acid) CAS 2706-90-3		4.4 ppt	● ABOVE GUIDELINE
Nitrate CAS 14797-55-8		1.4 ppm	● ABOVE GUIDELINE
PFHxA (perfluorohexanoic acid) CAS 307-24-4		5.5 ppt	● ABOVE GUIDELINE
Arsenic CAS 7440-38-2		0.50 ppb	● ABOVE GUIDELINE

PFBS (perfluorobutane sulfonic acid) <small>CAS 375-73-5</small>		4.2 ppt	● WITHIN LIMITS
Fluoride <small>CAS 16984-48-8</small>		0.70 ppm	● WITHIN LIMITS
Lead <small>CAS 7439-92-1</small>		3.0 ppb	● WITHIN LIMITS
PFDoA (perfluorododecanoic acid) <small>CAS 307-55-1</small>		ND	● NOT DETECTED
PFHpS (perfluoroheptane sulfonic acid) <small>CAS 375-92-8</small>		ND	● NOT DETECTED
9Cl-PF3ONS (9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid) <small>CAS 756426-58-1</small>		ND	● NOT DETECTED
ADONA (4,8-dioxa-3H-perfluorononanoic acid) <small>CAS 919005-14-4</small>		ND	● NOT DETECTED
HFPO-DA / GenX (hexafluoropropylene oxide dimer acid) <small>CAS 13252-13-6</small>		ND	● NOT DETECTED
4:2 FTS (4:2 fluorotelomer sulfonic acid) <small>CAS 757124-72-4</small>		ND	● NOT DETECTED
8:2 FTS (8:2 fluorotelomer sulfonic acid) <small>CAS 39108-34-4</small>		ND	● NOT DETECTED
11Cl-PF3OUdS (11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid) <small>CAS 763051-92-9</small>		ND	● NOT DETECTED
6:2 FTS (6:2 fluorotelomer sulfonic acid) <small>CAS 27619-97-2</small>		ND	● NOT DETECTED
NEtFOSAA (N-ethyl perfluorooctane sulfonamido acetic acid) <small>CAS 2991-50-6</small>		ND	● NOT DETECTED
PFUnA (perfluoroundecanoic acid) <small>CAS 2058-94-8</small>		ND	● NOT DETECTED
PFDA (perfluorodecanoic acid) <small>CAS 335-76-2</small>		ND	● NOT DETECTED
PFPeS (perfluoropentane sulfonic acid) <small>CAS 2706-91-4</small>		ND	● NOT DETECTED
PFNA (perfluorononanoic acid) <small>CAS 375-95-1</small>		ND	● NOT DETECTED
PFHpA (perfluoroheptanoic acid) <small>CAS 375-85-9</small>		ND	● NOT DETECTED
Lithium <small>CAS 7439-93-2</small>		ND	● NOT DETECTED
NMeFOSAA (N-methyl perfluorooctane sulfonamido acetic acid) <small>CAS 2355-31-9</small>		ND	● NOT DETECTED
PFTTrDA (perfluorotridecanoic acid) <small>CAS 72629-94-8</small>		ND	● NOT DETECTED
PFTA (perfluorotetradecanoic acid) <small>CAS 376-06-7</small>		ND	● NOT DETECTED

Want to go further than filtration?

Your report shows 10 contaminants above health guidelines. A specialist at Drawn can give you an expert read on your specific profile — what to prioritise, which filters actually address it, and what optimisation looks like for your household.

WHAT A CONSULTATION COVERS

- ✓ Your contaminant profile explained in plain English
- ✓ Filter recommendations matched to what's actually in your water
- ✓ Optimisation options for households ready for that conversation

[Talk to a specialist at Drawn →](#)

20 min · Free · No obligation

DATA SOURCES & METHODOLOGY

Contaminant data from EPA Safe Drinking Water Information System (SDWIS), PWSID TX2200012, most recent monitoring period. PFAS data from UCMR5 (Unregulated Contaminant Monitoring Rule 5, 2023–2025). Status flags compare detected levels against EPA Maximum Contaminant Levels (legal limits) and EWG health-based guidelines (peer-reviewed, stricter). Full methodology at waterhealthcheck.com/methodology.

WaterHealthCheck is an independent water-health information service. We do not sell water filters. This report is for informational purposes only and does not constitute medical advice.

waterhealthcheck.com · Jul 2026