

Phoenix, AZ

City of Phoenix · Surface water

EPA PWSID: AZ0407025

DATA: EPA SDWIS · UCMR5

LAST READING: DEC 2024

WATERHEALTHCHECK.COM



Good

3 above EWG health guideline
0 above EPA legal limit
30 contaminants monitored




















Good — with 3 concerns

City of Phoenix meets all federal legal limits but 3 contaminants exceed EWG health guidelines. All contaminants within federal legal limits

● ALL CONTAMINANTS WITHIN FEDERAL LEGAL LIMITS

CONTAMINANTS TESTED 30 TOTAL

CONTAMINANT	VS MCL	LEVEL	STATUS
PFBA (perfluorobutanoic acid) <small>CAS 375-22-4</small>	<div style="width: 100%;"><div style="width: 100%;"></div></div>	5.2 ppt	● ABOVE GUIDELINE
PFBS (perfluorobutane sulfonic acid) <small>CAS 375-73-5</small>	<div style="width: 100%;"><div style="width: 100%;"></div></div>	11.4 ppt	● ABOVE GUIDELINE
Lead <small>CAS 7439-92-1</small>	<div style="width: 100%;"><div style="width: 10%;"></div></div>	2.7 ppb	● ABOVE GUIDELINE
Copper <small>CAS 7440-50-8</small>	<div style="width: 100%;"><div style="width: 100%;"></div></div>	ND	● WITHIN LIMITS
Total trihalomethanes (TTHMs) <small>CAS Various</small>	<div style="width: 100%;"><div style="width: 100%;"></div></div>	ND	● WITHIN LIMITS
Chlorine (residual) <small>CAS 7782-50-5</small>	<div style="width: 100%;"><div style="width: 100%;"></div></div>	< 0.01 ppm	● WITHIN LIMITS
Lithium <small>CAS 7439-93-2</small>	<div style="width: 100%;"><div style="width: 100%;"></div></div>	70.2 ppb	● WITHIN LIMITS
PFNA (perfluorononanoic acid) <small>CAS 375-95-1</small>	<div style="width: 100%;"><div style="width: 100%;"></div></div>	ND	● NOT DETECTED
11CI-PF3OUdS (11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid) <small>CAS 763051-92-9</small>	<div style="width: 100%;"><div style="width: 100%;"></div></div>	ND	● NOT DETECTED
PFOA (perfluorooctanoic acid) <small>CAS 335-67-1</small>	<div style="width: 100%;"><div style="width: 100%;"></div></div>	ND	● NOT DETECTED
PFDoA (perfluorododecanoic acid)	<div style="width: 100%;"><div style="width: 100%;"></div></div>	ND	● NOT DETECTED

HFPO-DA / GenX (hexafluoropropylene oxide dimer acid) CAS 13252-13-6		ND	● NOT DETECTED
9Cl-PF3ONS (9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid) CAS 756426-58-1		ND	● NOT DETECTED
6:2 FTS (6:2 fluorotelomer sulfonic acid) CAS 27619-97-2		ND	● NOT DETECTED
NEtFOSAA (N-ethyl perfluorooctane sulfonamido acetic acid) CAS 2991-50-6		ND	● NOT DETECTED
4:2 FTS (4:2 fluorotelomer sulfonic acid) CAS 757124-72-4		ND	● NOT DETECTED
8:2 FTS (8:2 fluorotelomer sulfonic acid) CAS 39108-34-4		ND	● NOT DETECTED
PFPeA (perfluoropentanoic acid) CAS 2706-90-3		ND	● NOT DETECTED
PFPeS (perfluoropentane sulfonic acid) CAS 2706-91-4		ND	● NOT DETECTED
PFDA (perfluorodecanoic acid) CAS 335-76-2		ND	● NOT DETECTED
PFHxA (perfluorohexanoic acid) CAS 307-24-4		ND	● NOT DETECTED
PFUnA (perfluoroundecanoic acid) CAS 2058-94-8		ND	● NOT DETECTED
ADONA (4,8-dioxo-3H-perfluorononanoic acid) CAS 919005-14-4		ND	● NOT DETECTED
PFHxS (perfluorohexane sulfonic acid) CAS 355-46-4		ND	● NOT DETECTED
PFOS (perfluorooctane sulfonate) CAS 1763-23-1		ND	● NOT DETECTED
PFHpS (perfluoroheptane sulfonic acid) CAS 375-92-8		ND	● NOT DETECTED
PFTTrDA (perfluorotridecanoic acid) CAS 72629-94-8		ND	● NOT DETECTED
PFTA (perfluorotetradecanoic acid) CAS 376-06-7		ND	● NOT DETECTED
PFHpA (perfluoroheptanoic acid) CAS 375-85-9		ND	● NOT DETECTED
NMeFOSAA (N-methyl perfluorooctane sulfonamido acetic acid) CAS 2355-31-9		ND	● NOT DETECTED

WATER WELLNESS · DRAWN HEALTH

Want to go further than filtration?

Your report shows 3 contaminants above health guidelines. A specialist at Drawn can give you an expert read on your specific profile — what to prioritise, which filters actually address it, and what optimisation looks like for your household.

WHAT A CONSULTATION COVERS

- ✓ Your contaminant profile explained in plain English
- ✓ Filter recommendations matched to what's actually in your water
- ✓ Optimisation options for households ready for that conversation

[Talk to a specialist at Drawn →](#)

20 min · Free · No obligation

DATA SOURCES & METHODOLOGY

Contaminant data from EPA Safe Drinking Water Information System (SDWIS), PWSID AZ0407025, most recent monitoring period. PFAS data from UCMR5 (Unregulated Contaminant Monitoring Rule 5, 2023–2025). Status flags compare detected levels against EPA Maximum Contaminant Levels (legal limits) and EWG health-based guidelines (peer-reviewed, stricter). Full methodology at waterhealthcheck.com/methodology.

WaterHealthCheck is an independent water-health information service. We do not sell water filters. This report is for informational purposes only and does not constitute medical advice.

waterhealthcheck.com · Dec 2024